



Product Service


CERTIFICATE

No. Z2 106727 0019 Rev. 03

Holder of Certificate: Tindo Operations Co Pty Ltd

6- 8 Park Way
Mawson Lakes SA 5095
AUSTRALIA

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic (PV) Modules

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 077-2243223-003

Valid until: 2030-05-12

Date, 2025-05-16

(In-Mo Sung)

CERTIFICATE

No. Z2 106727 0019 Rev. 03

Model(s):

144 cell Walara-xxxG3P(-BL/SL), xxx = 550 to 575 in step of 5 W
 132 cell Walara-xxxG3P(-BL/SL), xxx = 505 to 525 in step of 5 W
 120 cell Walara-xxxG3P(-BL/SL), xxx = 460 to 475 in step of 5 W
 108 cell Walara-xxxG3P(-BL/SL), xxx = 415 to 430 in step of 5 W
 144 cell Walara-xxxG4P(-BL/SL), xxx = 575 to 595 in step of 5 W
 132 cell Walara-xxxG4P(-BL/SL), xxx = 525 to 545 in step of 5 W
 120 cell Walara-xxxG4P(-BL/SL), xxx = 475 to 495 in step of 5 W
 108 cell Walara-xxxG4P(-BL/SL), xxx = 430 W, 433 W, 435 W, 440 W, 445 W

Remark: xxx is standing for rated output power at STC
 BL is standing for black backsheet with black frame
 SL is standing for silver frame with white backsheet
 Without BL or SL is standing for white backsheet with black frame

Brand Name:

Tindo solar



Parameters:

Safety class: Class II
 Max. System voltage: 1500 V DC
 Fire Safety Class: Class C according to UL 790
 Construction: Framed, with junction box, cable and connectors

Tested according to:

IEC 61215-1:2021
 IEC 61215-1-1:2021
 IEC 61215-2:2021
 IEC 61730-1:2016
 IEC 61730-2:2016
 EN 61215-1:2021
 EN 61215-1-1:2021
 EN 61215-2:2021
 EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06